

A.L. ABBOTT AND ASSOCIATES (PTY) LTD

(Reg. No. 1982/004379/07)

Consulting Analytical & Industrial Chemists
Specialists in Water & Waste Water Treatment
Telephone (021)448 6340/1
After Hours (021)712 0940
Telefax (021)448 6342
e-Mail Address :
info@alabbott.co.za



Doc.No. 5.10/1 Rev.3

No. 1, Vine Park
Vine Road
7925
P.O. Box 483
WOODSTOCK, CAPE
7915

Certificate of Analysis

OVERSTRAND MUNICIPALITY : SC 1466/2014

ANALYSIS

ONRUS MOND

DATE SAMPLED

2016/01/06

DATE RECEIVED :

2016/01/07

DATE ANALYSIS

COMMENCED :

2016/01/07

OUR REF. : 2016/01/06/295

REPORT NO. : 48

	Sample Number	295		
Mthd ALA No.	Analyses	Results	Coastal & Transitional Waters Limit	Inland Waters Limit
84	E.coli (count per 100 ml)	649	250	500
87	Enterococci (Faecal Streptococci) (count per 100 ml)	91	100	200

N. VAN BINSBERGEN (Pr.Sci.Nat.)
DIRECTOR
11 January 2016

TO: OVERSTRAND MUNICIPALITY
P O Box 20
HERMANUS
7200
Attention : LIEZL BEZUIDENHOUT (lbezuidenhout@overstrand.gov.za)

Cc: Patrick Robinson

Sampler : P. Jacquire

This report relates only to the samples tested and is issued subject to the company's standard terms and conditions of business.